

**Engine Co.5**  
Monthly Report  
September 2020

**Summary**

Engine Company 5 responded to 62 calls for service for the month of September. Company 5's surveys this month include, 3 Schools, 2 Apartments and 2 Shopping Plazas.

**Personnel**

All Station 5 personnel are currently in their assigned positions. There are several vacancies at Station 5 created from promotions.

**Apparatus/Equipment**

Engine 5 has a portable radio out of service again this month for inability to transmit. Engine 5 was out for several minor repairs this month and is back in service. A new battery powered hurst tool was put in service this month replacing the old gasoline powered unit. This compact unit is much smaller and takes up less space on the truck giving us more storage space.

**Fire Stations/Facilities**

Station 5 had its boiler repaired this month after the system was inspected and a leaking boiler collar was discovered. The Plymo-Vent was discovered to be leaking in rain water after heavy rains at the close of the month, this was passed along to DPW. After last month's tropical storm it was discovered that the generator at Station 5 is not wired properly, we did not have power to critical circuits like the house radios. This issue is being looked at by DPW but has not been resolved yet.

**Miscellaneous**

Nothing to report.

Captain E.Scott England

Chief M. Flynn